



Operation and Maintenance Manual

Table of Contents

Chapter 1	Page
- Product Introduction	3
- Product Warranty	3-4
- Safe Operating Procedures	4-5
Chapter 2	Page
- System Description	6
- System Specifications	6
Chapter 3	Page
- Operating Instructions	<i>7-9</i>
- Recommended Foam	7
 Preventative Maintenance Checks and Services 	<i>7-8</i>
Chapter 4	Page
- Training	10
Chapter 5	Page
- Maintenance	11
- Servicing and Maintenance Activities	12-16
- Troubleshooting	16-17
Chapter 6	Page
- Pictures	18-20

Chapter 1

Introduction

1-1. Manufacturer

a. The Enforcer 30 is Manufactured by:

Enforcer One, LLC 473 Dividend Drive B Peachtree City, GA 30269 United States of America Phone: (678) 788-8413

Fax: (6787) 788-8415

E-mail: lnfo@enforcerone.com
Website: www.enforcerone.com

b. EnforcerOne is committed to the satisfaction of our owners and operators of the Enforcer 30. If you have any problems, questions, or concerns please contact EnforcerOne via phone, Fax, or E-mail.

1-2. Warranty

Limited Warranty



CAUTION: User should read and follow all Safety Rules and Operating Instructions BEFORE first use of this product!

Enforcer One, LLC warrants to the original owner-user that Enforcer One, LLC products will be free from failures due to defects in workmanship for a period of one year from the date of original purchase. During the warranty period, Enforcer One, LLC, at its sole discretion, will repair or replace at no charge, the product that, in its sole opinion, is defective.

The purchaser is responsible for packing the product for shipment and for charges to ship the product to the location specified by Enforcer One, LLC, including, at the purchasers sole discretion, insurance on the shipment. Enforcer One, LLC will return the product pre-paid to the purchaser.

If the product has been altered, modified or repaired in any way, or if the failure is the result of misuse, abuse or misapplication without the prior consent of Enforcer One, LLC, this warranty shall be void and Enforcer One, LLC shall have no obligation to repair or replace the failed product.

The use of any foam product other than a FIREBULL® Fluorine Free Foam product will void the warranty.

Warranty - continued

When used in conjunction with sound fire management practices and strictly as per the manufacturer's instructions, the products may provide protection against anticipated fires and may accelerate the extinguishing of existing fires.



CAUTION: The unpredictable nature of fires, the techniques used to apply product(s) as well as the knowledge-understanding and judgment of the individual(s) attempting to extinguish or control them will affect the performance of Enforcer One, LLC product(s).

THIS WARRANTY IS THE SOLE AND EXCLUSIVE WARRANTY FOR ENFORCER ONE, LLC PRODUCT(S) AND DISCLAIMS AND EXCLUDES ANY AND ALL IMPLIED WARRANTIES REGARDING THE PRODUCT(S) INCLUDING BUT NOT LIMITED TO, ANY IMPLIED WARRANTY OF MERCHANTABILITY OR IMPLIED WARRANTY OF FITNESS FOR A PARTICULAR PURPOSE.

No person or entity is authorized to bind Enforcer One, LLC to any other warranty obligation or liability to distributer, purchaser or any third party for any loss of profits, economic loss, indirect, incidental, punitive, special or consequential damages whatsoever and howsoever caused. Operation or use of this or any Enforcer One, LLC product for which this warranty is issued shall constitute acceptance of the terms hereof.



CAUTION: Prior to attempting to operate this or any Enforcer One, LLC product, you MUST read and understand all directions and instructions in this user manual. Until you have read and understand all CAUTIONS; Warnings, Requirements, Instructions for Set-up & Testing - Operation and Maintenance: NO ATTEMPT should be made to operate this or any Enforcer One, LLC product. In order to assure that your Enforcer One, LLC product(s) are ready when needed, they must be regularly maintained as outlined. FAILURE TO COMPLY WITH ALL CAUTIONS, WARNINGS, REQUIREMENTS, INSTRUCTIONS, PROCEDURES AND MAINTENANCE WILL VOID THIS WARRANTY & MAY RESULT IN SERIOUS INJURY OR DEATH &/OR DAMAGE TO OR LOSS OF PROPERTY.

SAFE OPERATING REQUIREMENTS

1. <u>DO NOT</u> attempt to use this or any Enforcer One, LLC product(s) if they appear damaged and/or broken. Missing or damaged components MUST be properly repaired or replaced as soon as possible.

- 2. **DO NOT** attempt to use this or any Enforcer One, LLC product(s) if you are tired, injured or under the influence of drugs, medication or alcohol.
- 3. <u>DO</u> keep children and bystanders away from the area where Enforcer One, LLC product(s) are in-use.
- 4. **DO NOT** attempt to use this or any Enforcer One, LLC product(s) in the event that the fire represents a situation that is beyond the capabilities of the Operator and/or the Equipment.
- 5. <u>DO</u> follow the proper Set-up, Testing, and Maintenance & Inspection Procedures to assure that your Enforcer One, LLC product(s) is/are ready for use when needed.
- 6. **DO** exit the area IMMEDIATELY if progress in fighting the fire is not being made and **DO NOT** return to the area.
- 7. <u>DO</u> comply with all local Laws & Regulations related to the proper use, installation, maintenance, training and inspection of Fire-Fighting Equipment.



WARNING: The act of fighting fire is both hot and dangerous work. Smoke, heat, unseen fumes/gases and flames can be easily underestimated. In the absence of the proper training, protective gear and clothing, extreme caution should be exercised to avoid serious injury or death. If ever, in an attempt to extinguish a fire, you are unsure that progress is being made, contain the fire (if possible) and move quickly and safely away from the threat.

ADDITIONAL INFORMATION

http://www/usfa.fema.gov/safety/sheets.htm

http://www.nfpa.org/education/index.html

http://www.ilpi.com/safety/extinguishers.html

http://www.Enforcer One, LLC.com

1-3. Manual Changes

- 1. EnforcerOne will provide equipment update changes to this manual on an as need basis.
- 2. This manual and associated updates will be posted on the EnforcerOne web site.
- 3. This manual supersedes all previous Operating Instructions for the Enforcer 30 system.

System Description

2-1. General Information

The Enforcer 30 Compressed Air Foam System utilizes compressed air to propel firefighting foam. Enforcer 30 produces air aspirated foam providing a thick vapor sealing blanket that will inhibit re-ignition. The Enforcer 30 will produce up to 300 gallons of finished foam with discharge duration of up to 2 ½ minutes. The system can be easily recharged by the end user.

2-2. Model Configuration

The Enforcer 30 consists of a Premix Tank which holds 30 gallons of pre-mixed FIREBULL® Fluorine Free Foam. Two compressed air cylinders are attached to the Premix Tank through a regulator and hose assembly. One 50' section of lay flat hose and one pistol grip style Nozzle.

2-3. Specifications

- Height: 38.5 " (97.79 cm) Length: 54.5" (138.34 cm) Depth: 42" (106.68 cm.)
 Empty Weight: 495 lbs. (224.5 kg) Loaded Weight: 995lbs. (451.3 kg)
- Premix Tank: 30 US Gallons (227 I)
- Finished Foam Capacity: 1200 US Gallons (6814 I)
- **Foam Discharge Distance**: Up to 95 Feet (29 m)
- Air Cylinders: 90 cu. ft. 2200 psi (151.6 bar)
- Recharge Time: 3-5 minutes

2-4. Transporting

The Enforcer 30 should be secured when transporting in trailers or vehicles.

Operating Instructions

3-1. Initial Setup

The Enforcer 30 comes fully assembled. The **30 gallon Premix Tank** and **Compressed Air Cylinder** must be filled prior to use. The proper FIREBULL® Fluorine Free Foam product should be selected based on operational ambient temperatures and type of anticipated fires <u>before</u> putting the unit into service.

3-2. FIREBULL® Fluorine Free Foam Products

- a. Enforcer 3 Backpack should only be used with FIREBULL® Fluorine Free Foam products mixed at a 1%, 3% or 6% solution for low, medium and high expansion.
- b. It is recommended that a FIREBULL® Freeze Protected Fluorine Free Foam Product be used when positioning the unit outside during extended subfreezing weather.

3-3. System Depressurization



Ensure the system is depressurized before conducting maintenance

- a. Close the Air Cylinder Valves.
- b. Open nozzle until all air is deployed and working pressure gauge reads *zero* or open Pressure Relief Valve.

3-4. Preventative Maintenance Checks & Services (PMCS)

- a. It is recommended that the PMCS CHECKLIST be completed every month.
- b. Personnel conducting the PMCS should be thoroughly familiar with the Enforcer 30 system and the information contained in this manual.

Preventative Maintenance Checks and Services (PMCS)



ne	Signature
_ 1.	Conduct a visual inspection of the system for chaffing or loose hose(s), dirt, corrosion or damage.
2.	Check the Air Cylinder for normal operating pressure (1800-2200 psi).
	a. Ensure System is depressurized.
	b. Disconnect Air Cylinders and pull out of unit.
	c. Connect Air Cylinder Pressure Check Gauge.
	 d. Open Air Cylinder and check for normal operating pressure. (1800- 2200psi)
	 e. Close Air Cylinder and slowly disconnect Pressure Check Gauge allowing for pressure bleed off.
	f. If the Air Cylinder pressure is <i>below</i> 1500 psi remove, recharge and replace the Air Cylinder.
	The Air Cylinder should normally be left in the closed position.
3.	Check the Premix Tank Level
	a. Disconnect fill tower Cap check liquid level.
	b. Fill up the Premix Tank if low.
4.	Check the tire condition.
	Note any other Problems:

3-5. Operating Instructions



Warning

Always refer to the product MSDS for proper precautions and treatment(s) if foam is accidently ingested or sprayed in eyes, mouth or nose

- Extend hose ensure the Nozzle and the Foam Discharge Valve are in the closed position.
- b. Charge the system by turning one of the Air Cylinder Valves counter clockwise.
- c. Open the Foam Discharge Valve slowly to the full open position.
- d. Grasp the nozzle with hand.
- e. Aim the nozzle at the base of the fire and open valve to discharge foam.

3-6. Cold Weather Operations

a. It is recommended that a FIREBULL® Fluorine Free Foam Pre-Mix product is used when freezing is anticipated.

3-7. Emergency Procedures

a. Loose Hose

- 1. Go to the unit and close the Foam Discharge Valve.
- 2. Go to the Nozzle and close the valve.

b. No Foam Discharge

- 1. Check to see if Air Cylinder is full.
- 2. Verify the Air Cylinder Valve is turned completely on.
- 3. Ensure Air Pressure Hose is attached properly.
- 4. Check for obstruction in discharge hose.

c. Shut Down Procedures

- 1. Close the Nozzle Valve.
- 2. Close the Air Cylinder Valve.
- 3. Open Nozzle valve to depressurize the system or open Pressure Relief Valve.
- 4. Secure discharge hose.

Training

4-1. Training Program

- a. Training on the Enforcer 30 should be conducted or reviewed annually for all operators
- b. Maintenance personnel should complete initial training and refresher training as required
- c. Trainers should be thoroughly familiar with the system, fire behavior, hazard identification, and basic firefighting techniques
- d. Operator training should be accomplished in live fire scenarios. Live fire training can often be accomplished through coordination with a local fire department.

4-2. Training Program of Instructions

a. Operators and Maintenance Personnel

- 1. PMCS
- 2. Normal and Cold Weather Operating Instructions
- 3. Emergency Procedures
- 4. Operation in live fire scenario

b. Maintenance Personnel

- 1. General Maintenance
- 2. Instructions and Technical Assistance
- 3. Foam Product
- 4. Maintenance Log
- 5. Servicing Under Normal and Cold Conditions
- 6. Scheduled Maintenance
- 7. Unscheduled Maintenance
- 8. Troubleshooting Procedures
- 9. Storage and Protection

Maintenance

5.1 General Instructions

- a. It is recommended that the preventative and maintenance (PMCS) be conducted monthly.
- b. It is recommended that qualified personnel be assigned the responsibility to service and maintain the system
- c. All maintenance activity should be documented and should include copies of the completed PMCS Checklist, Premix Tank Filling Calendar, type/ ratio of product used, component changes and any other problems encountered. A MSDS should be maintained for the type of foam being used.

5-2. Technical Assistance

Maintenance personnel should contact EnforcerOne whenever any problem arises that cannot be solved using the information in this manual or when unusual situations are encountered or expected.

Enforcer 30 Maintenance Log

Preventative Maintenance Checks and Services (PMCS)

Refer to Chapter 5 – Maintenance for specific activities

Maintenance Activity	Date Completed	Performed By	Notes/Comments

Maintenance Activity	Recommended Interval	Date Due	Date Completed	Performed By:
Air Cylinder Pressure Check	Every 6 months			
Air Cylinder – Visual Inspection	Annually			
Air Regulator Inspection	Every 2 years			
Air Cylinder Hydrostatic Test	Every 5 Years			
Premix Cylinder and Discharge Hose Hydrostatic Test	Every 5 Years			

Unscheduled Maintenance

Maintenance Activity	Date Completed	Performed By	Comments/Notes

5-7. Servicing Under Normal Conditions

a. System Pressure Check

- 1. Make sure that the Fill Tower Cap is <u>secure</u>, the Foam Discharge Valve and Pressure Relief Valve are <u>closed</u>.
- 2. *Open* the Air Cylinder Valve and check the air pressure on the *High Pressure Gauge* for *normal operating pressure of 1800-2200psi*.
- 3. Check the Working Pressure Gauge is in the normal operating position 150psi.
- 4. Conduct a leak check if the High Pressure Gauge reads **below** 1500 psi or if the Working Pressure Gauge reads **below** 150 psi.
 - a. Spray a soap solution on all airlines/fittings.
 - b. Tighten leaking fittings, replace O-rings, or replace defective components
- 5. Bleed off any stored pressure through Pressure Relief Valve.

b. Changing and Servicing Air Cylinder



Ensure the system is depressurized before conducting any maintenance on the system. Extreme care should be used when transporting the Air Cylinder(s).

- 1. Ensure Air Cylinder Valves are closed
- 2. Depressurize the system
- 3. Lift out the Air Cylinders
- 4. Have the Air Cylinders filled to 2200 psi by a certified technician
- 5. Replace the Air Cylinders in the holder
- 6. Reconnect the Air Cylinders

c. Refilling the Premix Tank

- 1. Close the Air Cylinder Valve
- 2. Ensure System is depressurized
- 3. Unscrew Fill Cap
- 4. Add water until Premix Tank is full
- 5. Add appropriate amount of foam to an empty pail or drum
- 6. Add the water to the foam and mix to thin the concentrate
- 7. Using a long spout funnel add the thinned concentrate to the unit (Ensure the funnel extends to the lower portion of the tank, the concentrate solution will push the clear water out of the top ensuring a perfect fill)
- 8. Replace Fill Cap ensuring it is tightened properly
- 9. <u>Important Note:</u> The Premix Tank Manifold should be tightened by hand. <u>Do not</u> use any wrenches or Teflon tape or thread sealant on any of the Premix tank fittings.

5-8. Servicing In Cold or Freezing Conditions

Fill the Premix Tank with FIREBULL® Fluorine Free Foam Freeze Protected Premix solution whenever temperatures are below 32 degrees Fahrenheit. FIREBULL® Fluorine Free Foam is a solution made by Enforcer One, LLC. The Pre-Mix solution is already mixed, this means Water and Foam, no need for mixing onsite. Maintenance personal should open the Pre-Mix bucket and fill the Enforcer unit full of the Pre-Mix solution.

5-9. Scheduled Maintenance Interval Recommendations

Component	Maintenance Activity and Recommended Interval
Air Cylinder	Check pressure - every 6 months
	 Visual inspection and certification – annually
	Hydrostatic testing – every 5 years
Cleaning	Wash with soap and water – minimum annually
Air Regulator	Check Operation – every 2 years
Premix Tank	Pressurize and check for leaks – annually
&	 Hydrostatic testing should be completed every 5 years
Discharge Hose	
Foam Solution	Follow Foam Manufacturer quality testing recommendations

5-10. Unscheduled Maintenance

Unscheduled maintenance will need to be performed as required.

5-11. Trouble Shooting the System

Users should contact Enforcer One if malfunctions cannot be corrected after employing good troubleshooting practices. Use the matrix on page 17 for assistance.

Problem or Symptom	Possible Solution
No Pressure on Gauges	Air Cylinder Valve is not turned on
	 Air Cylinder is empty
	 Pressure Gauge is inoperative
	 Broken or blocked air hose
	 Air Regulator has malfunctioned
Foam Does Not Discharge	 Premix Tank is empty
From Hose	 Air Cylinder is empty
	 Air Cylinder is not turned on
	 Nozzle is in the off position
	 Nozzle valve has malfunctioned
	 Blockage on dispensing hose
	 Foam solution is frozen
Air line Leak	 Air hose fittings are loose or broken
	 Air line is pinched, cracked or
	broken
System is Not Fully Discharging	 There is insufficient volume of air in the Air Cylinder
	 The Foam Discharge Nozzle is not
	fully opening
	 The Foam Discharge Hose has a
	restriction
	 The Air Regulator has a malfunction
	 The Foam solution is frozen or near
	freezing
	 There is a blockage in the Premix Tank

5-12. Storage and Protection

- a. The Enforcer 30 does not have any special storage requirements if stored inside.
- b. A protective cover is recommended and should be used if the equipment is stored outside as this will reduce sun damage to hoses and gauges.